



**JANUARY 2, 2024**

**Members of the Board**

Sylvia C. Wilson  
*Chair Person*  
Shannah Tharp-Gilliam, Ph.D.  
Harry Readshaw  
Emily Kinkead  
Paul Klein  
Theresa Kail-Smith  
Darrin Kelly

**CONTRACT NO. 1796**

**FURNISH AND DELIVER SODIUM HYPOCHLORITE**

**ADDENDUM NO. 1**

Arletta Scott Williams  
*Executive Director*

Douglas A. Jackson, P.E.  
*Director  
Operations & Maintenance*

Michelle M. Buys, P.E.  
*Director  
Environmental Compliance*

Kimberly N. Kennedy, P.E.  
*Director  
Engineering & Construction*

Karen Fantoni, CPA, CGMA  
*Director  
Finance*

Michael Lichte, P.E.  
*Director  
Regional Conveyance*

Jeanne K. Clark  
*Director  
Governmental Affairs*

Julie Motley-Williams  
*Director  
Administration*

All bidders bidding **Contract No. 1796** shall read and take note of this **Addendum No. 1**. The Procurement Documents for **Contract No. 1796 FURNISH AND DELIVER SODIUM HYPOCHLORITE** are hereby revised and/or clarified as stated below.

**Acknowledgement of Contract No. 1796 Addendum No. 1**

The Acknowledgement attached to **Addendum No. 1** is to be signed and returned immediately via email to **Kathleen P. Uniatowski** at [kathleen.uniatowski@alcosan.org](mailto:kathleen.uniatowski@alcosan.org) and acknowledged with Bidder's Proposal.

A handwritten signature in blue ink that reads "Kimberly Kennedy". The signature is written in a cursive style and is positioned above a horizontal line.

**Kimberly Kennedy, P.E.**

Director – Engineering and Construction

## ADDENDUM NO. 1

### Clarifications:

1.) The following questions were received:

What are the approximate usage volumes by each site for Sodium Hypochlorite? What are the approximate delivery amounts per each site?

The response is as follows:

We have four sites at the plant that use sodium hypochlorite. The main location consists of 3 outside tanks used for disinfection of the wastewater, one 22,000 gallon and two 21,000 gallon tanks. ALCOSAN can receive between 10 to 2 full tanker trucks per week. High usage time is the summer and low usage time is the winter.

The other three sites are at various odor control buildings. We typically top off these sodium hypochlorite storage tanks in these buildings from one of the delivery trucks that comes in for the main location. The buildings are listed below.

402 Building, has one 6,000-gallon tank which gets topped off about every 1.5 months.

420 Building has two 475-gallon tanks which gets topped off about once a month.

720 Building has two 475-gallon tanks which gets topped off about twice a month.

**ACKNOWLEDGEMENT OF**

**CONTRACT NO. 1796**

**FURNISH AND DELIVER SODIUM HYPOCHLORITE**

**ADDENDUM NUMBER 1**

**FIRM NAME:** \_\_\_\_\_

**SIGNATURE:** \_\_\_\_\_

**TITLE:** \_\_\_\_\_

**DATE:** \_\_\_\_\_